

# 9-30781

## AirSense ModuLaser, Standard display module

### General

---

ModuLaser is a scalable aspirating smoke detection solution that makes installation easier, maintenance quicker, and takes applications further than traditional air sampling detectors. Two basic module types comprise the ModuLaser solution: a display module, and a detector module. Each detector module can accommodate up to 250 meters combined sampling pipe. Display modules and detector modules communicate by RS-485 interconnections.

Display modules are available in three configurations: Standard with TFT color display, status LED's and navigation buttons, Minimum with only status LED's, and Command which is similar to the Standard but with the added functionality to control various modules over SenseNET. The Minimum and Standard Display Modules can each support up to 8 detector modules, while the Command Display Module can support up to 127 modules across the SenseNET network.

### Standard display module

---

The Standard Display Module features a user interface which consist of a TFT color display, navigation buttons and status LED's. Configuration of the Standard Display Module (and associated detectors modules) can be done via the user interface, via a computer using Remote software or via SenseNET using a Command Display Module. The TFT color display support simple operations like changing configuration options via a menu driven structure, but also advanced features like viewing the chart recording in graphical format.

The Standard Display Module has two USB ports, one master and one slave. The master is used to connect a pen drive/memory stick, which in turn can be used for storing the configuration, the event logs or chart recordings, or for firmware upgrade purposes. While the USB slave is used to connect to a computer.

### Perfect solution

---

Thanks to advanced features that make it virtually impervious to dust and dirt, ModuLaser is ideal for use in hostile environments that would disable other kinds of smoke detectors. Forward scattering optical detection adds early warning capability without the risk of nuisance alarms normally associated with high sensitivity smoke detection, while exclusive environmental compensation technology adds a high degree of reliability to an already solid detection solution.



### Details

---

- Modular Design : Separate centrally-controllable detector modules allow efficient piping and discrete zones with no overlap.
- Zoned aspirating smoke detection : Individual detector modules provide detection for individual areas or zones, specific zone alarm information can be transmitted to the main fire alarm panel via a common APIC address card in the display module or through dedicated alarm relays within each detector module.
- Simplified installation : Ingenious docking station design allows detectors to be easily connected together as a group. Sensitive electronics are easily removed to ensure they will not be damaged during first fix installation. Aspirating pipework and cable entries can easily be made into either the top or the bottom of the unit.
- Intuitive user interface : Bright easy-to-see color TFT display and universal navigation and control buttons take the guesswork out of programming and diagnostics.
- Easy pipe connection : The quick fit pipe adaptor system locks down securely, yet leaves plenty of room for easy pipe connection and removal.
- Quick location of smoke : Each detector module is self-contained, which means no delays in determining in which zone (sampling pipe) smoke is present.

# 9-30781

## AirSense ModuLaser, Standard display module

### Technical specifications

#### General

|                   |  |
|-------------------|--|
| Status indication | LED's  |
| User interface    | TFT and navigation buttons on Normal and Command Display Modules |
| Alarm levels      | 4 (Aux, Pre-alarm, Alarm and Alarm 2)                            |
| Event log         | 20 000 events per module   |
| RS485 support     | Yes (SenseNET and SenseNET+)                                     |
| Connectivity      | USB (x2), IP and APIC on Display Module                          |

#### Electrical

|                     |  |
|---------------------|--|
| Operating voltage   | 18 to 30 VDC   |
| Current consumption | Display Module (at 24 VDC):<br>204 mA - Minimum Display Module<br>232 mA - Standard Display Module<br>232 mA - Command Display Module<br>Detector Module (at 24 VDC):<br>260 mA - fan speed 1<br>380 mA - fan speed 6 (default speed)<br>940 mA - fan speed 16 |

#### Detection

|                            |   |
|----------------------------|---|
| Detection principle        | Laser light scattering mass detection and particle evaluation |
| Particle sensitivity range | 0.003 to 10 microns   |

#### Sampling pipe

|                         |  |
|-------------------------|--|
| Length                  | Up to 250 m (820 ft.) combined per detector module   |
| Quantity sampling holes | Up to 20 - Class A per detector module<br>Up to 40 - Class B per detector module<br>Up to 50 - Class C per detector module |
| Inlet size              | 27 or 25 mm (1.06 or 0.98 in) outer diameter   |
| Inlet location          | Top or bottom  |
| Exhaust size            | 27 or 25 mm (1.06 or 0.98 in) outer diameter   |
| Exhaust location        | Top or bottom  |
| Inlet quantity          | 1 per detector module  |

#### Input

|                       |                        |
|-----------------------|------------------------|
| Input quantity        | 2 per module           |
| Input type and rating | Supervised             |
| Termination           | 15 K $\Omega$ 5% 1/4 W |
| Programmable          | Yes                    |

#### Output

|                        |   |
|------------------------|---|
| Output quantity        | 3 per module  |
| Output type and rating | Voltage free (contact rating 2 A at 30 VDC / NO/NC/C) |
| Programmable           | Yes   |

#### Physical

|                             |   |
|-----------------------------|---|
| Physical dimensions         | W x D x H<br>110.5 x 133.5 x 300 mm<br>(4.35 x 5.25 x 11.8 in)  |
| Net weight                  | Display Module:<br>1.18 Kg (2.6 lb.)<br>Detector Module:<br>1.57 Kg (3.46 lb.)                          |
| Colour                      | Grey-white (RAL 9002)   |
| Mounting type               | Surface mount   |
| Cable entries               | 2 at the bottom, 2 at the rear, 2 at the top on Detector Module, and 3 at the top on the Display Module |
| Cable entry size            | 20 mm (0.5 in) - top and bottom   |
| Detector module orientation | Vertical (0 deg or 180 deg)   |

#### Environmental

|                       |  |
|-----------------------|--|
| Operating temperature | Equipment:<br>-10 to +60°C (14 to +140°F)<br>Sampled air:<br>-20 to +60 °C (-4 to +140 °F) |
| Relative humidity     | 0 to 95% noncondensing   |
| Environment           | Indoor   |
| IP rating             | IP40   |

#### Regulatory

|               |                                       |
|---------------|---------------------------------------|
| Compliance    | REACH, RoHS                           |
| Certification | BOSEC, CPR, CSIRO, EN54-20, LPCB, VdS |

#### Chart recorder

|                 |   |
|-----------------|---|
| Sampling period | Adjustable between 1s and 60 s  |
| Capacity        | 1 months @ 1s / Up to 5 years @ 60 s  |
| Values recorded | Detector value, 4 alarm level values, flow value and temperature (all simultaneously) |

#### Compatible products

| Category         | Reference | Description                                |
|------------------|-----------|--|
| Detection device | 9-30780   | AirSense ModuLaser, Minimum Display Module |
| Detection device | 9-30782   | AirSense ModuLaser, Command display module |
| Detection device | 9-30783   | AirSense ModuLaser, Detector module device |



As a company of innovation, Kidde Global Solutions reserves the right to change product specifications without notice. For the latest product specifications, visit [firesecurityproducts.com](http://firesecurityproducts.com) online or contact your sales representative.

Last updated on 12 January 2026 - 15:44